

Hidden Markov Model and States Prediction of an Autonomous Wind-Diesel Complex

Yuriy E. Obzherin¹, Stanislav M. Sidorov^{2*}, and Sergey N. Fedorenko³

¹Sevastopol State University, Department of Higher Mathematics, 299053 Sevastopol, Russia

²Sevastopol State University, Department of Higher Mathematics, 299053 Sevastopol, Russia

³Sevastopol State University, Department of Technological Processes and Production Automation, 299053 Sevastopol, Russia

Abstract. The problem of assessing the reliability and analyzing the functioning of an autonomous wind-diesel complex, consisting of a wind power plant, working and standby diesel generators, an inverter and a storage battery, is considered. First, a semi-Markov model of an autonomous wind-diesel complex is built, which makes it possible to calculate the stationary and temporal reliability characteristics. Then, on its basis, a hidden Markov model is developed, which is used to solve the problems of predicting and evaluating its characteristics, taking into account the given parameters and the signal vector. The results of the study are obtained in a general form and are invariant with respect to the laws of distribution of random variables describing the elements of an autonomous wind-diesel complex. They allow you to simulate the functioning of the system under various distribution laws, based on statistical data, without modifying the model itself.

Introduction

Currently, renewable energy sources are being introduced into power supply system's everywhere. The combined use of wind turbines and diesel generators contributes not only to economic benefits, but also to the reduction of emissions of fuel processing products. [10, 2] However, the efficiency of wind turbines depends on many factors, in particular, on the wind load, which is stochastic. In this regard, the problem arises of constructing adequate mathematical models that take into account the stochastic nature of work and the natural resources used (for example, wind) and the presence of a diesel generator (backup energy source).

The article [3] considers an approximate model of a wind-diesel complex in Matlab\Simulink. Articles [4, 5] present the results of simulation studies. In [6, 7], the assessment of the operating modes of the power supply complex with a wind-diesel power plant is studied. In [1, 2], Markov models are used to analyze the functioning of a wind-diesel complex. It should be noted that most of the results obtained by other authors consider cases where the random variables describing the system have an exponential distribution (Markov model). The semi-Markov model proposed in this article allows the use of distributions of an arbitrary form. It also allows you to find the time characteristics of the reliability and efficiency of the system, in contrast to the Markov model.

Secondly, for territorially remote systems (or systems controlled remotely), the operator is not always able to completely obtain the information contained in the encoding of the states of the semi-

Markov model when changing their states, but it is always possible to obtain some signal (information) associated with the states of the nested chain Markov, which can be considered unobservable (hidden). In such cases, the use of the theory of hidden Markov models makes it possible to solve the problems of finding and estimating characteristics based on the observed signal vector. The purpose of our work is to apply the theory of semi-Markov processes with a common phase space of states and the theory of hidden Markov models for the analysis of reliability and efficiency of an autonomous wind-diesel complex (WDC).

This article discusses the problem of assessing the reliability and analysis of the functioning of an autonomous WDC, consisting of a wind power plant, working and standby diesel generators, an inverter and a storage battery.

In this paper, first, a semi-Markov model [8-12] of an autonomous WDC is constructed, which makes it possible to calculate the stationary and temporal characteristics of reliability. Then, following the methodology proposed by the authors [18], a hidden Markov model [15-17] is developed on its basis, which is used to solve forecasting problems and evaluate its characteristics, taking into account the given parameters.

1 Semi-Markov model of an autonomous WDC

Consider system S, which is an autonomous wind-diesel complex. We will consider the inverter and the

*Corresponding author: xaevac@mail.ru

battery to be absolutely reliable in the sense that the probability of their failure is much less than the probability of failure of other elements. Therefore, we will not take them into account when constructing a semi-Markov model. Then the system S can be represented as a three-element system with a time reserve: element 1 is a wind turbine, element 2 is a diesel generator (DG), element 3 is a reserve diesel generator (RDG) (time reserve). The failure of element 1 should be understood as any event that leads to disruption of normal functioning (for example, lack of wind, failure of one of the components, etc.). The system functions as follows: if element 1 (2) fails, then element 2 (1) is switched off, element 3 is switched on, and the system operates due to the reserve of time (element 3). As soon as element 1 (2) is restored, element 3 is switched off (in this case, we assume that by the next time its characteristics are fully restored), and element 2 (1) starts working with the previous level of operating time. System failure occurs when element 1 (2) is on recovery, element 2 (1) is disabled, and the reserve time ends (failure of element 3). The reserve of time ends if either the fuel of the backup generator runs out (time of operation due to the reserve of fuel), or it fails.

Let's assume that the uptime of elements 1 and 2 are described by random variables (RV) α_1 and α_2 , respectively, having distribution functions $F_1(x) = P(\alpha_1 \leq x)$, $F_2(x) = P(\alpha_2 \leq x)$ and density distributions $f_1(x)$, $f_2(x)$, and the recovery time - by random variables β_1 and β_2 , having distribution functions $G_1(x) = P(\beta_1 \leq x)$, $G_2(x) = P(\beta_2 \leq x)$ and distribution density $g_1(x)$, $g_2(x)$. A random instantly replenished reserve of time is considered, which is described by RV τ having the distribution function $R(x) = P(\tau \leq x)$ and distribution density $r(x)$. Random variables α_1 , α_2 , β_1 , β_2 , τ are assumed to be independent and have finite mathematical expectations. It should be noted that SV τ is the minimum of the operating time due to the fuel reserve of the standby generator and its uptime.

On fig. 1 is shown a block diagram of the system under consideration.

Consider the discrete-continuous phase space of states of the system under consideration:

$$E = \{1112x_2, 2112x_1, 1021x_2, 2201x_1, 3020x_1x_2, 3200x_1x_2\} \quad (1).$$

Phase states are designated according to the following scheme: the first digit of the code indicates the number of the element in which the state change occurred; the rest of the numbers - what happens to each element (1 - work, 2 - disabled, 0 - recovery). The continuous components show the time remaining until the next state change.




Fig. 1. Structural diagram of the considered system

Let's decipher the values of the status codes:

- 1112 x_2 (2112 x_1) – element 1(2) has been restored, element 2(1) is enabled, element 3 is disabled, x_2 (x_1) – time until the end of element 2(1) operation.
- 1021 x_2 (2201 x_1) – element 1(2) fails and starts recovery, element 2(1) turns off, element 3 turns on, x_2 (x_1) time until element 2(1) ends.
- 3020 x_1x_2 (3200 x_1x_2) – system failure: x_1 (x_2) – time until the end of element 1(2) restoration, x_2 (x_1) – time until the end of element 2(1) operation.

Let's write down the probabilities of transitions between the states of the system:

$$P_{1112x_2}^{2201x_1} = f_1(x_2 + x_1), x_1 > 0;$$

$$P_{1112x_2}^{1021y_2} = f_1(x_2 - y_2), 0 < y_2 < x_2;$$

$$P_{2112x_1}^{1021x_2} = f_2(x_1 + x_2), x_2 > 0;$$

$$P_{2112x_1}^{2201y_1} = f_2(x_1 - y_1), 0 < y_1 < x_1;$$

$$P_{1021x_2}^{1112x_2} = \int_0^\infty g_1(t)\bar{R}(t)dt = P(\tau > \beta_1);$$

$$P_{1021x_2}^{3020x_1x_2} = \int_0^\infty r(t)g_1(x_1 + t)dt;$$

$$P_{2201x_1}^{2112x_1} = \int_0^\infty g_2(t)\bar{R}(t)dt = P(\tau > \beta_2);$$

$$P_{2201x_1}^{3200x_1x_2} = \int_0^\infty r(t)g_2(x_2 + t)dt;$$

$$P_{3020x_1x_2}^{1112x_2} = 1, \quad P_{3200x_1x_2}^{2112x_1} = 1. \quad (2)$$

Let's write down the system of equations for finding the stationary distribution of the embedded Markov chain.

$$\left\{ \begin{aligned} \rho(1112x_2) &= \rho(1021x_2) \int_0^\infty g_1(t)\bar{R}(t)dt + \\ &+ \int_0^\infty \rho(3020x_1x_2)dx_1, \\ \rho(2112x_1) &= \rho(2201x_1) \int_0^\infty g_2(t)\bar{R}(t)dt + \\ &+ \int_0^\infty \rho(3200x_1x_2)dx_2, \\ \rho(1021x_2) &= \int_{x_2}^\infty f_1(y_2 - x_2) \rho(1112y_2)dy_2 + \\ &+ \int_0^\infty f_2(x_2 + x_1) \rho(2112x_1)dx_1, \\ \rho(2201x_1) &= \int_{x_1}^\infty f_2(y_1 - x_1) \rho(2112y_1)dy_1 + \\ &+ \int_0^\infty f_1(x_1 + x_2) \rho(1112x_2)dx_2, \\ \rho(3020x_1x_2) &= \rho(1021x_2) \int_0^\infty r(t)g_1(x_1 + t)dt, \\ \rho(3200x_1x_2) &= \rho(2201x_1) \int_0^\infty r(t)g_2(x_2 + t)dt, \\ \int_E \rho(e)de &= 1 \text{ (normalization condition)}. \end{aligned} \right. \quad (3)$$

Let's substitute equation 5 into equation 1 of system (3). We'll get

$$\begin{aligned} \rho(1112x_2) &= \rho(1021x_2) \int_0^\infty g_1(t)\bar{R}(t)dt + \\ &+ \rho(1021x_2) \int_0^\infty dx_1 \int_0^\infty r(t)g_1(x_1 + t)dt = \\ &= \rho(1021x_2) \left[\int_0^\infty g_1(t)\bar{R}(t)dt \right. \\ &\quad \left. + \int_0^\infty dx_1 \int_0^\infty r(t)g_1(x_1 + t)dt \right] = \\ &= \rho(1021x_2) \left[\int_0^\infty g_1(t)\bar{R}(t)dt \right. \\ &\quad \left. + \int_0^\infty r(t)dt \int_0^\infty g_1(x_1 + t)dx_1 \right] = \\ &= \rho(1021x_2) \left[\int_0^\infty g_1(t)\bar{R}(t)dt + \int_0^\infty r(t)\bar{G}_1(t)dt \right] = \\ &= \rho(1021x_2). \end{aligned}$$

Similarly, substituting equation 6 into equation 2 of system (3), we obtain:

$$\rho(2112x_1) = \rho(2201x_1).$$

Consequently, system (3) is reduced to the form:

$$\left\{ \begin{aligned} \rho(1021x_2) &= \int_{x_2}^\infty f_1(y_2 - x_2) \rho(1021y_2)dy_2 + \\ &+ \int_0^\infty f_2(x_2 + x_1) \rho(2201x_1)dx_1, \\ \rho(2201x_1) &= \int_{x_1}^\infty f_2(y_1 - x_1) \rho(2201y_1)dy_1 + \\ &+ \int_0^\infty f_1(x_1 + x_2) \rho(1021x_2)dx_2. \end{aligned} \right. \quad (4)$$

The solution to system (4) was found in [12] and has the form:

$$\begin{aligned} \rho(1112x_2) &= \rho(1021x_2) = \rho_0 \bar{F}_2(x_2), \\ \rho(2112x_1) &= \rho(2201x_1) = \rho_0 \bar{F}_1(x_1), \\ \rho(3020x_1x_2) &= \rho_0 \bar{F}_2(x_2) \int_0^\infty r(t)g_1(x_1 + t)dt, \\ \rho(3200x_1x_2) &= \rho_0 \bar{F}_1(x_1) \int_0^\infty r(t)g_2(x_2 + t)dt, \end{aligned} \quad (5)$$

the constant ρ_0 is found from the normalization condition.

Stay times in system states:

$$\begin{aligned} \theta_{1112x_2} &= \alpha_1 \wedge x_2, & \theta_{2112x_1} &= \alpha_2 \wedge x_1, \\ \theta_{1021x_2} &= \beta_1 \wedge \tau, & \theta_{2201x_1} &= \beta_2 \wedge \tau, \\ \theta_{3020x_1x_2} &= x_1, & \theta_{3200x_1x_2} &= x_2. \end{aligned} \quad (6)$$

where \wedge is the sign of the minimum.

Then the average residence times in the states are equal to:

$$\begin{aligned} E\theta_{1112x_2} &= \int_0^{x_2} \bar{F}_1(t)dt, & E\theta_{2112x_1} &= \int_0^{x_1} \bar{F}_2(t)dt, \\ E\theta_{1021x_2} &= \int_0^\infty \bar{G}_1(t)\bar{R}(t)dt, \\ E\theta_{2201x_1} &= \int_0^\infty \bar{G}_2(t)\bar{R}(t)dt. \end{aligned} \quad (7)$$

$$E\theta_{3020x_1x_2} = x_1, \quad E\theta_{3200x_1x_2} = x_2.$$

We divide the state space E into two non-overlapping subsets: healthy (E_+) and failure states (E_-):

$$\begin{aligned} E_+ &= \{1112x_2, 2112x_1, 1021x_2, 2201x_1\}, \\ E_- &= \{3020x_1x_2, 3200x_1x_2\} \end{aligned}$$

Let's find the stationary characteristics of the system reliability.

Using transition probabilities (2), stationary distribution (5), average residence times in states (7), we obtain:

$$\begin{aligned} \int_{E_+} m(x)\rho(dx) &= \rho_0 \int_0^\infty \bar{F}_2(x_2)dx_2 \int_0^\infty \bar{G}_1(t)\bar{R}(t)dt + \\ &+ \rho_0 \int_0^\infty \bar{F}_1(x_1)dx_1 \int_0^\infty \bar{G}_2(t)\bar{R}(t)dt + \\ &+ \rho_0 \int_0^\infty \bar{F}_2(x_2)dx_2 \int_0^{x_2} \bar{F}_1(t)dt + \\ &+ \rho_0 \int_0^\infty \bar{F}_1(x_1)dx_1 \int_0^{x_1} \bar{F}_2(t)dt = \\ &= \rho_0 E\alpha_2 E(\beta_1 \wedge \tau) + \rho_0 E\alpha_1 E(\beta_2 \wedge \tau) + \\ &+ \rho_0 E\alpha_1 E\alpha_2. \end{aligned}$$

$$\begin{aligned} \int_{E_+} P(x, E_-)\rho(dx) &= \\ &= \rho_0 \int_0^\infty dx_1 \int_0^\infty \bar{F}_2(x_2)dx_2 \int_0^\infty r(t)g_1(x_1 + t)dt + \end{aligned}$$

$$\begin{aligned}
 & +\rho_0 \int_0^\infty dx_2 \int_0^\infty \bar{F}_1(x_1) dx_1 \int_0^\infty r(t) g_2(x_2 + t) dt = \\
 & = \rho_0 E \alpha_2 \int_0^\infty r(t) \bar{G}_1(t) dt + \rho_0 E \alpha_1 \int_0^\infty r(t) \bar{G}_2(t) dt = \\
 & = \rho_0 E \alpha_2 P(\beta_1 > \tau) + \rho_0 E \alpha_1 P(\beta_2 > \tau). \\
 & \int_{E_-} m(x) \rho(dx) = \\
 & = \rho_0 \int_0^\infty x_1 dx_1 \int_0^\infty \bar{F}_2(x_2) dx_2 \int_0^\infty r(t) g_1(x_1 + t) dt + \\
 & + \rho_0 \int_0^\infty x_2 dx_2 \int_0^\infty \bar{F}_1(x_1) dx_1 \int_0^\infty r(t) g_2(x_2 + t) dt = \\
 & = \rho_0 E \alpha_2 \int_0^\infty x_1 dx_1 \int_0^\infty r(t) g_1(x_1 + t) dt + \\
 & + \rho_0 E \alpha_1 \int_0^\infty x_2 dx_2 \int_0^\infty r(t) g_2(x_2 + t) dt.
 \end{aligned}$$

Using the results obtained in [18, p. 61],

$$\begin{aligned}
 \int_{E_-} m(x) \rho(dx) & = \rho_0 E \alpha_2 [E \beta_1 - E(\beta_1 \wedge \tau)] + \\
 & + \rho_0 E \alpha_1 [E \beta_2 - E(\beta_2 \wedge \tau)].
 \end{aligned}$$

$$\begin{aligned}
 \int_E m(x) \rho(dx) & = \int_{E_-} m(x) \rho(dx) + \int_{E_+} m(x) \rho(dx) = \\
 & = \rho_0 E \alpha_2 [E \beta_1 - E(\beta_1 \wedge \tau)] + \\
 & + \rho_0 E \alpha_1 [E \beta_2 - E(\beta_2 \wedge \tau)] + \rho_0 E \alpha_2 E(\beta_1 \wedge \tau) + \\
 & + \rho_0 E \alpha_1 E(\beta_2 \wedge \tau) + \rho_0 E \alpha_1 E \alpha_2 = \\
 & = \rho_0 [E \alpha_1 E \alpha_2 + E \alpha_2 E \beta_1 + E \alpha_1 E \beta_2].
 \end{aligned}$$

Where indicated above:

$m(x)$ – average residence times in states, $P(x, E_-)$ – probabilities of transition from operable to failure states, $E(\beta \wedge \tau)$ – mathematical expectation of the minimum of two RVs, $P(\beta > \tau)$ – mathematical expectation of that RV β is greater than RV τ ,

$$P(\beta > \tau) = \int_0^\infty r(t) \bar{G}(t) dt,$$

$$E(\beta \wedge \tau) = \int_0^\infty \bar{G}(t) \bar{R}(t) dt.$$

Using the formulas presented in [12, 13] and the expressions found above, we obtain:

- mean stationary uptime T_+ :

$$\begin{aligned}
 T_+ & = \frac{\int_{E_+} m(x) \rho(dx)}{\int_{E_+} P(x, E_-) \rho(dx)} = \\
 & = \frac{E \alpha_2 E(\beta_1 \wedge \tau) + E \alpha_1 E(\beta_2 \wedge \tau) + E \alpha_1 E \alpha_2}{E \alpha_2 P(\beta_1 > \tau) + E \alpha_1 P(\beta_2 > \tau)},
 \end{aligned}$$

- average stationary recovery time T_- :

$$\begin{aligned}
 T_- & = \frac{\int_{E_-} m(x) \rho(dx)}{\int_{E_+} P(x, E_-) \rho(dx)} = \\
 & = \frac{E \alpha_2 [E \beta_1 - E(\beta_1 \wedge \tau)] + E \alpha_1 [E \beta_2 - E(\beta_2 \wedge \tau)]}{E \alpha_2 P(\beta_1 > \tau) + E \alpha_1 P(\beta_2 > \tau)},
 \end{aligned}$$

- stationary availability factor F_a :

$$\begin{aligned}
 F_a & = \frac{\int_{E_+} m(x) \rho(dx)}{\int_E m(x) \rho(dx)} = \\
 & = \frac{E \alpha_2 E(\beta_1 \wedge \tau) + E \alpha_1 E(\beta_2 \wedge \tau) + E \alpha_1 E \alpha_2}{E \alpha_1 E \alpha_2 + E \alpha_2 E \beta_1 + E \alpha_1 E \beta_2}.
 \end{aligned}$$

In the case of a non-random slack, i.e. when $R(x) = 1(x - h)$ where h is the value of the time reserve, stationary characteristics of reliability will take the form:

- mean stationary uptime T_+ :

$$T_+ = \frac{E \alpha_2 \int_0^h \bar{G}_1(t) dt + E \alpha_1 \int_0^h \bar{G}_2(t) dt + E \alpha_1 E \alpha_2}{E \alpha_2 \bar{G}_1(h) + E \alpha_1 \bar{G}_2(h)}, \quad (8)$$

- average stationary recovery time T_- :


$$T_- = \frac{E \alpha_2 \int_h^\infty \bar{G}_1(t) dt + E \alpha_1 \int_h^\infty \bar{G}_2(t) dt}{E \alpha_2 \bar{G}_1(h) + E \alpha_1 \bar{G}_2(h)}, \quad (9)$$

- stationary availability factor F_a :

$$F_a = \frac{E \alpha_2 \int_0^h \bar{G}_1(t) dt + E \alpha_1 \int_0^h \bar{G}_2(t) dt + E \alpha_1 E \alpha_2}{E \alpha_1 E \alpha_2 + E \alpha_2 E \beta_1 + E \alpha_1 E \beta_2}. \quad (10)$$

As an illustrative example of the use of formulas (8)-(9), consider the system S, for which, before the start of its operation, it is assumed that the RVs $\alpha_1, \alpha_2, \beta_1, \beta_2$ have an Erlang distribution of order IV and $E \alpha_1 = 150$ h, $E \alpha_2 = 100$ h, $E \beta_1 = 24$ h, $E \beta_2 = 20$ h, and the time reserve h varies from 10 to 20 hours.

The results obtained are shown in fig. 2.



a)




Fig. 2. Graphs of stationary reliability characteristics for different values of the reserve time h : a) mean uptime, b) mean recovery time, c) stationary availability factor.

2 Finding the transition probabilities of the enlarged semi-Markov model

To construct a hidden Markov model (HMM), we enlarge the stationary distributions (5) in terms of continuous components, i.e. we apply the algorithm of stationary phase enlargement to each state. Note that the phase space of semi-Markov states is obtained by adding to the codes of physical states a set of continuous components that fix the residual times of the action of factors that change the state of the system. [13] It is desirable to enlarge these continuous components, leaving only a discrete set of physical states.

We'll get

$$\begin{aligned} \int_0^\infty \rho(1112x_2)dx_2 &= \int_0^\infty \rho(1021x_2)dx_2 = \\ &= \rho_0 \int_0^\infty \bar{F}_2(x_2)dx_2 = \rho_0 E\alpha_2, \\ \int_0^\infty \rho(2112x_1)dx_1 &= \int_0^\infty \rho(2201x_1)dx_1 = \\ &= \rho_0 \int_0^\infty \bar{F}_1(x_1)dx_1 = \rho_0 E\alpha_1, \\ \int_0^\infty \int_0^\infty \rho(3020x_1x_2)dx_1 dx_2 &= \end{aligned}$$

$$\begin{aligned} &= \rho_0 \int_0^\infty \bar{F}_2(x_2)dx_2 \int_0^\infty x_1 dx_1 \int_0^\infty r(t)g_1(x_1 + t)dt = \\ &= \rho_0 E\alpha_2 \int_0^\infty r(t)\bar{G}_1(t)dt = \rho_0 E\alpha_2 P(\beta_1 > \tau). \\ &\int_0^\infty \int_0^\infty \rho(3200x_1x_2)dx_1 dx_2 = \\ &= \rho_0 \int_0^\infty \bar{F}_1(x_1)dx_1 \int_0^\infty x_2 dx_2 \int_0^\infty r(t)g_2(x_2 + t)dt = \\ &= \rho_0 E\alpha_1 \int_0^\infty r(t)\bar{G}_2(t)dt = \rho_0 E\alpha_1 P(\beta_2 > \tau). \end{aligned}$$

Consequently, the discrete phase space of enlarged states of the system under consideration has the form:

$$\hat{E} = \{1112, 2112, 1021, 2201, 3020, 3200\}.$$

Using the formulas presented in [12, p. 36],

$$\hat{p}_k^r = \frac{\int_{E_k} \rho(de)P(e, E_r)}{\rho(E_k)}, \quad \hat{m}_k = \frac{\int_{E_k} \rho(de)m(e)}{\rho(E_k)} \quad (11)$$

we find the probabilities of transitions \hat{p}_k^r between the enlarged states and the average sojourn times \hat{m}_k in them.

Let's calculate the denominators of formulas (11).

$$\begin{aligned} \rho(E_{1112}) &= \rho(E_{1021}) = \rho_0 E\alpha_2, \\ \rho(E_{2112}) &= \rho(E_{2201}) = \rho_0 E\alpha_1, \\ \rho(E_{3020}) &= \rho_0 E\alpha_2 P(\beta_1 > \tau), \\ \rho(E_{3200}) &= \rho_0 E\alpha_1 P(\beta_2 > \tau). \end{aligned}$$

Average sojourn times \hat{m}_k equals:

$$\begin{aligned} \hat{m}_{1112} &= \frac{\int_0^\infty \bar{F}_2(x_2)dx_2 \int_0^{x_2} \bar{F}_1(t)dt}{E\alpha_2}, \\ \hat{m}_{2112} &= \frac{\int_0^\infty \bar{F}_1(x_1)dx_1 \int_0^{x_1} \bar{F}_2(t)dt}{E\alpha_1}, \\ \hat{m}_{1021} &= \frac{\int_0^\infty \bar{F}_2(x_2)dx_2 \int_0^\infty \bar{G}_1(t)\bar{R}(t)dt}{E\alpha_2} = E(\beta_1 \wedge \tau), \\ \hat{m}_{2201} &= E(\beta_2 \wedge \tau), \\ \hat{m}_{3020} &= \frac{E\beta_1 - E(\beta_1 \wedge \tau)}{P(\beta_1 > \tau)}, \\ \hat{m}_{3200} &= \frac{E\beta_2 - E(\beta_2 \wedge \tau)}{P(\beta_2 > \tau)}. \end{aligned}$$

Let's find the transition probabilities \hat{p}_k^r :

$$\begin{aligned} \hat{p}_{1112}^{1021} &= \frac{\int_0^\infty \bar{F}_2(x_2)dx_2 \int_0^{x_2} f_1(x_2 - t)dt}{E\alpha_2} = \\ &= \frac{E\alpha_2 - E(\alpha_1 \wedge \alpha_2)}{E\alpha_2}, \\ \hat{p}_{1112}^{2201} &= \frac{E(\alpha_1 \wedge \alpha_2)}{E\alpha_2}, \quad \hat{p}_{2112}^{1021} = \frac{E(\alpha_1 \wedge \alpha_2)}{E\alpha_1}, \end{aligned}$$

$$\hat{p}_{2112}^{2201} = \frac{E\alpha_1 - E(\alpha_1 \wedge \alpha_2)}{E\alpha_1},$$

$$\hat{p}_{1021}^{1112} = P(\tau > \beta_1), \quad \hat{p}_{1021}^{3020} = P(\tau < \beta_1),$$

$$\hat{p}_{2201}^{2112} = P(\tau > \beta_2),$$

$$\hat{p}_{2201}^{3200} = P(\tau < \beta_2), \quad \hat{p}_{3020}^{1112} = 1, \quad \hat{p}_{3200}^{2112} = 1.$$

Then the matrix of transition probabilities \hat{P}_i^j between the enlarged states of the system is equal to:

$$\hat{P}_i^j = \begin{pmatrix} 0 & 0 & \frac{E\alpha_2 - E(\alpha_1 \wedge \alpha_2)}{E\alpha_2} & \frac{E(\alpha_1 \wedge \alpha_2)}{E\alpha_2} & 0 & 0 \\ 0 & 0 & \frac{E(\alpha_1 \wedge \alpha_2)}{E\alpha_1} & \frac{E\alpha_1 - E(\alpha_1 \wedge \alpha_2)}{E\alpha_1} & 0 & 0 \\ P(\tau > \beta_1) & 0 & 0 & 0 & P(\tau < \beta_1) & 0 \\ 0 & P(\tau > \beta_2) & 0 & 0 & 0 & P(\tau < \beta_2) \\ 1 & 0 & 0 & 0 & 0 & 0 \\ 0 & 1 & 0 & 0 & 0 & 0 \end{pmatrix}$$

3 Hidden Markov model of the system under consideration

For a complete description of the HMM [16, 17], it is necessary to determine:

1. The set of model states corresponds to the set of states of the enlarged model \hat{E} .
2. Observable sequence alphabet (set of signals).

Let's assume that during the functioning of the system S, the states of the EMC of the enlarged model are not observed (hidden states), but only the number of operable elements is observed during the change of states of the HMM. We introduce the following set of signals:

$$J = \{0, 1, 2\},$$

where

- 0 - system failure;
- 1 - elements 1 and 2 of the system are functioning;
- 2 - the system is operational due to the backup diesel generator.

Many signals can be selected in different ways. The set of signals J is chosen in this form, because "Accurate" information about the number of operable main and redundant elements can be obtained for almost any system.

3. The matrix of transition probabilities between system states.

For our model, the transition probability matrix consists of the transition probabilities \hat{P}_i^j of the enlarged semi-Markov model.

4. Connection of model states with signals.

Consider the relationship between the states of the embedded Markov chain (EMC) of the enlarged model and signals, i.e. define the connection function $R(s|\mathbf{x})$ [16, 18]:

$$R(s|\mathbf{x}) = P(S_n = s | X_n = \mathbf{x}), \mathbf{x} \in \hat{E}, s \in J, \\ \sum_{s \in J} R(s|\mathbf{x}) = 1,$$

where S_n is the n-th signal.

We assume that signals 0 and 2 are emitted correctly with a probability of 0.99 and erroneously with a probability of 0.01.

The function $R(s|\mathbf{x})$ of the connection between the NCM states of the integrated digital model and the signals is presented in Table 1.

Table 1. The connection function between the merged model EMC states and the signals.

Condition, x	Signal, s		
	s=0	s=1	s=2
1112	0	1	0
2112	0	1	0
1021	0.01	0	0.99
2201	0.01	0	0.99
3020	0.99	0	0.01
3200	0.99	0	0.01

5. The initial probability distribution of the model.

We will assume that at the initial moment of time the enlarged model can be equally likely to be in the state 1112 or 2112.

The HMM is built on the basis of the enlarged semi-Markov model.

4 Evaluation of characteristics and prediction of states

As an illustrative example, consider a system S, for which, before starting its operation, it is assumed that the CVs $\alpha_1, \alpha_2, \beta_1, \beta_2$ have an Erlang distribution of order IV and $E\alpha_1 = 150$ h, $E\alpha_2 = 100$ h, $E\beta_1 = 24$ h, $E\beta_2 = 20$ h, $E\tau = 15$ h. It is assumed that at the initial time the system is in states 1112 and 2112 with probabilities of 0.5.

Suppose that as a result of the operation of the system S, the following vector of signals is received:

$$\bar{s}_{30} = (1, 2, 1, 2, 1, 2, 1, 2, 0, 1, 2, 1, 2, 1, 2, 0, 1, 2, 1, 2, 0, 1, \\ 2, 1, 2, 1, 2, 1, 2, 1), \quad n=30.$$

Consider the problem of estimating the characteristics of a hidden Markov model, taking into account the introduced parameters, following [18, 19].

1. Let's determine the probabilities of states of the hidden model at the moment of emission of the 30th signal (the last signal in the chain).

Because the 30th signal is equal to 1 (elements 1 and 2 of the system are functioning), then the task is to determine the probability of finding the enlarged system in states leading to the emission of the specified signal. As a result, we get that at the 30th step the enlarged model with a probability of 0.3553 was in state 1112, with a probability of 0.6447 in state 2112. For other states, this probability is equal to zero.




Fig. 4. The trellis of maximized transition probabilities for considered chain of signals

2. Let's find the probabilities with which the hidden model will make the transition to the states at the next 31st step.

The probabilities of the transition of the hidden model at the 31st step: to state 1021 with a probability of 0.419, to state 2201 – 0.581, to all others – with zero.

3. Let's determine the probabilities of the appearance of signals at the next 31st step.

We get that the probability of the appearance of signal 2 at the 31st step is 0.99, signal 0 – 0.01, signal 1 – 0.

4. Let's find the probability of occurrence (emission) of the received signal vector \bar{s}_{30} .

The probability of occurrence of the received signal vector \bar{s}_{30} is equal to 0.00000243.

5. Forecasting the states of the hidden model based on the received signal vector.

Table 2 shows the most probable states of the hidden model at the transitions indicated in it and the probabilities of these states.

Table 2. Most probable states of the hidden model on transitions.

Transition number	1	7	11	17	21	26	29
Most likely state	1112	2112	2201	2112	3200	2112	2201
State probability	0.5233	0.6737	0.652	0.519	0.5136	0.6132	0.6447

Applying the Baum-Welsh algorithm [15, 16], we obtain an overestimated matrix of transition probabilities for the system under consideration. The original transition probability matrix and the transition probability matrix after reassessment are presented in Fig. 3.

Applying the Viterbi algorithm [15, 16] to the overestimated model, we determine the most probable chain of states for the received signal vector: 2201, 3200, 2112, 2201, 2112, 1021, 3020, 1112, 2201, 2112, 1021, 2112, 2201, 2112, 1021, 2112.

The trellis diagram for the first 12 received signals is shown on fig. 4. For simplicity, the following recoding of model states is used: 1112↔1, 2112↔2, 1021↔3, 2201↔4, 3020↔5, 3200↔6. The most probable states (according to the Viterbi algorithm for the overestimated model) for the vector of received signals are marked with a thick line. Thin lines connect other possible states that the system could achieve without information about the signal vector.

$$\begin{pmatrix}
 0 & 0 & 0.1454 & 0.8546 & 0 & 0 \\
 0 & 0 & 0.5697 & 0.4303 & 0 & 0 \\
 0.2606 & 0 & 0 & 0 & 0.7394 & 0 \\
 0 & 0.3469 & 0 & 0 & 0 & 0.6531 \\
 1 & 0 & 0 & 0 & 0 & 0 \\
 0 & 1 & 0 & 0 & 0 & 0
 \end{pmatrix}$$

a)

$$\begin{pmatrix}
 0 & 0 & 0.1283 & 0.8717 & 0 & 0 \\
 0 & 0 & 0.5369 & 0.4631 & 0 & 0 \\
 0.7075 & 0 & 0 & 0 & 0.2925 & 0 \\
 0 & 0.8066 & 0 & 0 & 0 & 0.1934 \\
 1 & 0 & 0 & 0 & 0 & 0 \\
 0 & 1 & 0 & 0 & 0 & 0
 \end{pmatrix}$$

b)

Fig. 3. Transition probability matrices:
 a) original transition probability matrix P_i^j ,
 b) overestimated transition probability matrix \bar{P}_i^j .

Discussions

The results of this article open up great opportunities for evaluating the functioning of autonomous wind-diesel complexes. The article shows how to apply the apparatus of the theory of hidden Markov models (used for systems with a finite set of states) to semi-Markov models that have a common phase space of states, which expands the possibilities of applying the HMM theory.

The article provides only illustrative examples showing the expansion of the possibilities of modeling

autonomous wind-diesel complexes using the methodology developed by the authors. However, it is obvious that it will not be difficult for energy specialists to use the parameters of real wind-diesel complexes as input data for models with subsequent calculation of characteristics.

It should be noted that the results obtained, with proper reformulation, can be used to analyze the functioning of technical systems for various purposes.

Conclusion

In this work, a semi-Markov model of an autonomous WDC is constructed, which allows calculating the stationary and temporal reliability characteristics. Then, on its basis, a hidden Markov model was developed, which is used to find estimates of the characteristics of an autonomous WDC and predict its states based on the signal vector obtained as a result of the operation. The results of the study will make it possible to predict the operating modes of an autonomous WDC. The resulting HMM allows you to re-evaluate the parameters of the constructed model (train) to increase its adequacy, according to the signals received in the process of functioning.

The results of the study are obtained in a general form and are invariant with respect to the distribution laws of random variables that describe the elements of an autonomous WDC. They allow you to simulate the functioning of the system under various distribution laws, based on statistical data, without modifying the model itself. In the future, it is planned to generalize the results for the case of a fleet (consisting of N pieces) of wind-diesel complexes.

The study was supported by the grant of the President of the Russian Federation for state support of young Russian scientists – Candidates of Sciences No. MK-329.2022.4.

References

1. A.V. Bobrov, V.A. Tremjasov, *Wind-diesel complexes in decentralized power supply: monograph* (Siberian Federal University, Krasnojarsk, 2012)
2. O.A. Grigor'eva, T.V. Krivenko, V.A. Tremjasov, Reliability analysis of an autonomous wind-diesel complex, Scientific and technical statements of the St. Petersburg State Polytechnic University, Vol. **2** (243), pp. 45–52. (2016)
3. S. Meziane, O. Feddaoui, R. Toufouti, Modeling and simulation of hybrid wind-diesel power generation system, International Journal of Renewable Energy, Vol. **8** (2), pp. 49–58. (2013)
4. R. Sebastián, A. Nevado, Study and Simulation of a Wind Hydro Isolated Microgrid. Energies, Vol. **13** (22):5937. (2020)
5. R. Sebastián, Modeling, Simulation and Control of Wind Diesel Power Systems. Energies, Vol. **15** : 1712. (2022)
6. Y.E. Shklyarskiy, D.E. Batueva. Operation mode selection algorithm development of a wind-diesel power plant supply complex. Journal of Mining Institute, Vol. **253**, pp. 115–126. (2022)
7. A.I. Baikov, A.B. Dar'enkov, E.N. Sosnina. Simulation Modeling of a Wind-Diesel Power Plant. Russ. Electr. Engin., Vol. **89**, 161–167 (2018).
8. N. Limnios, M. Nikulin. *Recent Advances in Reliability Theory: Methodology, Practice, and Inference*, eds. N. Limnios, M. Nikulin. (Springer Science+Business Media, New York, 2000)
9. Y.N. Rudenko, I.A. Ushakov. *Reliability of power systems*, 2nd edition. (Nauka, Novosibirsk, 1989)
10. Y.E. Obzherin. Semi-Markov and hidden Markov and semi-Markov models of energy systems. Proceedings of the Russian Academy of Sciences. Energy, Vol. **5**, pp. 26–32. (2019)
11. Y.E. Obzherin, S.M. Sidorov, M.M. Nikitin, Analysis of reliability and phase merging of systems with component-wise storages. Proceedings of the Russian Academy of Sciences. Energy, Vol. **6**, pp. 66–77. (2019)
12. .S. Korolyuk, A.F. Turbin, *Markovian restoration processes in the problems of system reliability* (Naukova Dumka, Kiev, 1982)
13. V.S. Korolyuk, V.V. Korolyuk, *Stochastic Models of Systems* (Springer Science+Business Media, Dordrecht, 1999)
14. V.J. Kopp, Y.E. Obzherin, A.I. Peschanskij, *Stochastic models of automated production systems with time redundancy*. (Izd-vo SevGTU, Sevastopol, 2000)
15. S. M. Ross, *Introduction to Probability Models, Ninth Edition* (Elsevier Academic Press, USA, 2006)
16. L.R. Rabiner, A Tutorial on Hidden Markov Models and Selected Applications in Speech Recognition, Proc. of the IEEE, Vol. **77** (2), pp. 257–286. (1989)
17. O. Cappe', E. Moulines, T. Ryde'n, *Inference in Hidden Markov Models* (Springer-Verlag, New York, 2005)
18. Y.E. Obzherin, M.M. Nikitin, S.M. Sidorov, Hidden Markov model based on signals from blocks of semi-markov system's elements and its application for dynamics analysis energy systems, Smart Innovation, Systems and Technologies. Singapore, Springer, Vol. **187**, pp. 477–486. (2021)
19. Y.E. Obzherin, M.M. Nikitin, S.M. Sidorov, *Hidden Markov model of maintenance by age of system elements*, in Methodological issues of reliability research of large energy systems. 92nd meeting of the seminar established at ISEM SB RAS. In 3 books, pp. 89–98. (2020)